

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	April 17 & April 24
Samples Taken By:	SM
Samples Taken By:	9:26am-9:56am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Primary School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
51	PS-CF-51	Room 102	Faucet	x	1.5			
52	PS-DW-52	Room 102	Bubbler (4/24)	x	2.0			
53	PS-DW-53	Room 103	Bubbler (4/24)	x	1.2			
54	PS-CF-54	Room 103	Faucet	x	<1.0			
55	PS-CF-55	Room 104	Faucet	x	2.6			
56	PS-DW-56	Room 104	Bubbler (4/24)	x	<1.0			
57	PS-DW-57	Room 105	Bubbler (4/24)	x	<1.0			
58	PS-CF-58	Room 105	Faucet	x	6.4			
59	PS-CF-59	Room 106	Faucet	x	<1.0			
60	PS-DW-60	Room 106	Bubbler (4/24)	x	<1.0			
61	PS-DW-61	Room 107	Bubbler (4/24)	x	1.1			
62	PS-CF-62	Room 107	Faucet	x	<1.0			
63	PS-DW-63	Room 108	Bubbler (4/24)	x	2.8			
64	PS-CF-64	Room 108	Faucet	x	<1.0			
65	PS-CF-65	Room 109	Faucet	x	<1.0			
66	PS-DW-66	Room 109	Bubbler (4/24)	x	7.1			
67	PS-CF-67	Room 110	Faucet	x	<1.0			
68	PS-DW-68	Room 110	Bubbler (4/24)	x	<1.0			
69	PS-DW-69	Room 111	Bubbler (4/24)	x	<1.0			
70	PS-CF-70	Room 111	Faucet	x	5.0			
71	PS-CF-71	Room 112	Faucet	x	1.8			
72	PS-DW-72	Room 112	Bubbler (4/24)	x	<1.0			
73	PS-DW-73	Room 113	Bubbler (4/24)	x	1.1			
74	PS-CF-74	Room 113	Faucet	x	1.4			
75	PS-CF-75	Room 114	Faucet	x	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		DW Drinking Water Fountain
Lab: Pace Labs		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	April 17 & April 24
Samples Taken By:	SM
Sample Draw Time:	8:45am-8:56am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Primary School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
1	PS-BF-1	Men's Restroom	Faucet	x	3.9			
2	PS-KF-2	Kitchen	Faucet	x	<1.0			
3	PS-KF-3	Kitchen	Faucet	x	<1.0			
4	PS-KF-4	Kitchen	Faucet	x	6.9			
5	PS-KF-5	Kitchen	Faucet	x	<1.0			
6	PS-KF-6	Kitchen Sprayer	Faucet	x	<1.0			
7-A	PS-KF-7-A	Faculty Room	Faucet- Left	x	4.8			
7-B	PS-KF-7-b	Faculty Room	Faucet- Right	x	5.2			
8	PS-BF-8	Kitchen Restroom	Faucet	x	<1.0			
9	PS-DW-9	Café	Bubbler	x	<1.0			
9-A	PS-DW-9-A	Café	Bubbler- Bottle Filler	x	<1.0			
10	PS-BF-10	Faculty Restroom	Faucet	x	<1.0			
11	PS-BF-11	Faculty Restroom	Faucet	x	14.4			
12	PS-BF-12	Nurse's Restroom	Faucet	x			40.6	Faucet is being replaced summer of 2021
13	PS-NF-13	Nurse's Office	Faucet	x	<1.0			
14	PS-CF-14	Copier Room	Faucet	x	4.7			
15	PS-BF-15	Room 201	Faucet	x			26.7	Posted- "Do Not Drink From This Outlet"
16	PS-DW-16	Room 202	Bubbler (4/24)	x	2.2			
17	PS-CF-17	Room 202	Faucet	x	<1.0			
18	PS-CF-18	Room 203	Faucet	x	1.2			
19	PS-DW-19	Room 203	Bubbler (4/24)	x	1.3			
20	PS-DW-20	Room 204	Bubbler (4/24)	x	2.1			
21	PS-CF-21	Room 204	Faucet	x	<1.0			
22	PS-CF-22	Room 205	Faucet	x	4.9			
23	PS-DW-23	Room 205	Bubbler (4/24)	x	<1.0			
24	PS-DW-24	Room 206	Bubbler (4/24)	x	<1.0			
25	PS-CF-25	Room 206	Faucet	x	1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
		DW Drinking Water Fountain
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		KBF Kitchen Bathroom Sink Faucet
Lab: Pace Labs		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection

**CLIENT INFORMATION**

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	April 17 & April 24
Samples Taken By:	SM
Samples Taken By:	9:26am-9:56am

**SCHOOL/PROJECT INFORMATION**

BLDG NO./NAME:	Primary School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

--	--	--	--	--

**SAMPLE DATA**

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
26	PS-CF-26	Room 207	Faucet	x	<1.0			
27	PS-DW-27	Room 207	Bubbler (4/24)	x	1.1			
28	PS-DW-28	Room 208	Bubbler (4/24)	x	1.9			
29	PS-CF-29	Room 208	Faucet	x	<1.0			
30	PS-CF-30	Room 210	Faucet	x	<1.0			
31	PS-DW-31	Room 210	Bubbler (4/24)	x	1.1			
32	PS-DW-32	Room 211	Bubbler (4/24)	x	<1.0			
33	PS-CF-33	Room 211	Faucet	x	1.1			
34	PS-CF-34	Room 212	Faucet	x	2.1			
35	PS-DW-35	Room 212	Bubbler (4/24)	x	<1.0			
36	PS-CF-36	Room 213	Faucet	x	5.0			
37	PS-DW-37	Room 213	Bubbler (4/24)	x	<1.0			
38	PS-DW-38	Room 214	Bubbler (4/24)	x	<1.0			
39	PS-CF-39	Room 214	Faucet	x	1.3			
40	PS-DW-40	Room 215	Bubbler (4/24)	x	<1.0			
41	PS-CF-41	Room 215	Faucet	x	4.5			
42	PS-CF-42	Room 216	Faucet	x	2.5			
43	PS-DW-43	Room 216	Bubbler (4/24)	x	<1.0			
44	PS-DW-44	Room 217	Bubbler (4/24)	x	<1.0			
45	PS-CF-45	Room 217	Faucet	x	1.5			
46	PS-LF-46	Library	Faucet	x	3.0			
47	PS-BF-47	HC Restroom	Faucet	x	2.9			
48	<del>PS-F-48</del>	<del>Boiler Room</del>	<del>Faucet</del>		N/A			No Sample
49	PS-CF-49	Room 101	Faucet	x	<1.0			
50	PS-DW-50	Room 101	Bubbler (4/24)	x	1.3			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

**CHAIN OF CUSTODY**

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
<b>INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only</b>		DW Drinking Water Fountain
Lab: Pace Labs		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection



## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	9:51am-10:14am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Middle School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501


## SAMPLE DATA

Sample Description ID (ID must match container label)

Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
1	MS-DW-1	Boy's Locker Room	Bubbler	x	<1.0			
2	MS-DW-2	Boy's Locker Room	Bubbler	x	<1.0			
2-A	MS-DW-2- A	Boy's Locker Room	Bubbler Bottle Filler	x	<1.0			
3	MS-F-3	Receiving	Faucet	x	1.9			
4	MS-BF-4	Kitchen Restroom	Faucet	x	<1.0			
5	MS-KF-5	Kitchen	Faucet	x	<1.0			
6	MS-KF-6	Kitchen	Faucet	x	3.9			
7	MS-KF-7	Kitchen	Faucet	x	<1.0			
8	MS-KF-8	Kitchen	Faucet	x	<1.0			
9	MS-KF-9	Kitchen	Faucet	x	<1.0			
10	MS-KF-10	Kitchen Sprayer	Faucet	x	<1.0			
11	MS-KF-11	Kitchen	Faucet	x	<1.0			
12	MS-KF-12	Kitchen	Faucet	x	<1.0			
13	MS-DW-13	Girl's Locker Room	Bubbler	x	<1.0			
14	MS-DW-14-A	Girl's Locker Room	Bubbler Bottle Filler	x	<1.0			
14-A	MS-DW-14	Girl's Locker Room	Bubbler	x	<1.0			
15	MS-NI-15	Nurse	Ice Machine	x	4.5			
16	MS-NF-16	Nurse	Faucet	x	<1.0			
17	MS-BF-17	Nurse	Faucet	x	<1.0			
18	MS-BF-18	Nurse	Faucet	x	<1.0			
19	MS-BF-19	Conf. Room	Faucet	x	<1.0			
20	MS-BF-20	Main Office	Faucet	x	<1.0			
21	MS-BF21	Main Office	Faucet	x	<1.0			
22	MS-DW-22	Main Lobby	Bubbler	x	<1.0			
23	MS-LF-23	Library Work Room	Faucet		N/A			No Used
24	MS-BF-24	100 Boy's Room	Faucet		N/A			Mixing Valve
25	MS-BF-25	100 Boy's Room	Faucet		N/A			Mixing Valve

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Date:	Legend
			BF Bathroom Faucet
			CF Classroom Faucet
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only			DW Drinking Water Fountain
Lab: Pace Labs			KBF Kitchen Bathroom Sink Faucet
			KF Kitchen Sink Faucet
			LF Library Faucet
Contact:			NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody			NF Nurse's Sink Faucet
			SC Service Connection

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	10:16am-10:44am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Middle School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
26	MS-DW-26	100 Wing	Bubbler	x	<1.0			
27	MS-DW-27	100 Wing	Bubbler	x	<1.0			
28	<del>MS-BF-28</del>	<del>100 Wing Girl's</del>	<del>Faucet</del>		<del>N/A</del>			Mixing Valve
29	<del>MS-BF-29</del>	<del>100 Wing Girl's</del>	<del>Faucet</del>		<del>N/A</del>			Mixing Valve
30	<del>MS-CF-30</del>	<del>Room 203</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
31	<del>MS-CF-31</del>	<del>Room 203</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
32	<del>MS-CF-32</del>	<del>Room 203</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
33	<del>MS-CF-33</del>	<del>Room 203</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
34	<del>MS-CF-34</del>	<del>Room 203</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
35	<del>MS-BF-35</del>	<del>200 Wing Boy's</del>	<del>Faucet</del>		<del>N/A</del>			Mixing Valve
36	<del>MS-BF-36</del>	<del>200 Wing Boy's</del>	<del>Faucet</del>		<del>N/A</del>			Mixing Valve
37	MS-DW-37	200 Wing	Bubbler	x	<1.0			
38	MS-DW-38	200 Wing	Bubbler	x	<1.0			
39	<del>MS-BF-39</del>	<del>200 Wing Girl's</del>	<del>Faucet</del>		<del>N/A</del>			Mixing Valve
40	<del>MS-BF-40</del>	<del>200 Wing Girls</del>	<del>Faucet</del>		<del>N/A</del>			Mixing Valve
41	<del>MS-CF-41</del>	<del>Room 202</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
42	<del>MS-CF-42</del>	<del>Room 202</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
43	<del>MS-CF-43</del>	<del>Room 202</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
44	<del>MS-CF-44</del>	<del>Room 202</del>	<del>Lab Faucet</del>		<del>N/A</del>			Under Construction
45	<del>MS-CF-45</del>	<del>Room 202</del>	<del>Lab Faucet</del>		<del>N/A</del>			N/A
46	MS-CF-46	Room 303	Lab Faucet	x	1.1			
47	MS-CF-47	Room 303	Lab Faucet	x	<1.0			
48	MS-CF-48	Room 303	Lab Faucet	x	<1.0			
49	MS-CF-49	Room 303	Lab Faucet	x	<1.0			
50	<del>MS-CW-50</del>	<del>Room 303</del>	<del>Lab Faucet</del>					DOES NOT EXIST

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		DW Drinking Water Fountain
Lab: Pace Labs		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	10:16am-10:44am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Middle School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
51	<del>MS-BF-51</del>	<del>300 Wing Boy's</del>	<del>Faucet</del>		N/A			Mixing Valve
52	<del>MS-BF-52</del>	<del>300 Wing Boy's</del>	<del>Faucet</del>		N/A			Mixing Valve
53	MS-DW-53	300 Wing	Bubbler	x	<1.0			
54	MS-DW-54	300 Wing	Bubbler	x	<1.0			
55	<del>MS-BF-55</del>	<del>300 Wing Girl's</del>	<del>Faucet</del>		N/A			Mixing Valve
56	<del>MS-BF-56</del>	<del>300 Wing Girl's</del>	<del>Faucet</del>		N/A			Mixing Valve
57	MS-CF-57	Room 302	Faucet	x	7.6			
58	MS-CF-58	Room 302	Faucet	x	1.0			
59	MS-CF-59	Room 302	Faucet	x	1.4			
60	MS-CF-60	Room 302	Faucet	x	<1.0			
61	MS-CF-61	Room 302	Faucet	x	3.2			
62	<del>MS-DW-62</del>	<del>LGI Hall Fountain</del>	<del>Bubbler</del>		N/A			No Longer Used
63	MS-DW-63	Executive Fountain	Bubbler	x	<1.0			
63-A	MS-DW-63-A	Executive Fountain	Bubbler Bottle Filler	x	<1.0			
64	MS-BF-64	Executive RR 1	Faucet	x	<1.0			
65	MS-BF-65	Executive RR 2	Faucet	x	<1.0			
66	MS-CF-66	Room 419	FACS	x	<1.0			
67	MS-CF-67	Room 419	FACS	x	<1.0			
68	<del>MS-CF-68</del>	<del>Band Room 404</del>	<del>Faucet</del>		N/A			N/A
69	<del>MS-CF-69</del>	<del>Room 417</del>	<del>Faucet</del>		N/A			Under Construction
70	<del>MS-CF-70</del>	<del>Room 417</del>	<del>Faucet</del>		N/A			Under Construction
71	<del>MS-CF-71</del>	<del>Room 418</del>	<del>Faucet</del>		N/A			Under Construction
72	<del>MS-CF-72</del>	<del>Room 418</del>	<del>Faucet</del>		N/A			Under Construction
73	<del>MS-CF-73</del>	<del>Room 411 tech</del>	<del>Faucet</del>		N/A			N/A
74	<del>MS-CF-74</del>	<del>Room 411 tech</del>	<del>Faucet</del>		N/A			N/A
75	<del>MS-CF-75</del>	<del>Room 411 tech</del>	<del>Faucet</del>		N/A			N/A

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
		DW Drinking Water Fountain
		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
		NI Nurse's Ice Machine
		NF Nurse's Sink Faucet
		SC Service Connection
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		
Lab: Pace Labs		
Contact:		
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		





## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Sample Draw Time:	10:15am-10:52am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	High School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501


## SAMPLE DATA

Sample Description ID (ID must match container label)		Outlet Information		First Draw	LAB RESULTS LEAD			REMEDIATION
Lab Sample #	Ichabod Sample No.	Location	Outlet Description		> 15ppb	15-19ppb	< 20ppb	
1	HS-BF-1	Main Office RR	Faucet	x			Mixing Valves	
2-A	HS-DW-2-A	Main Lobby	Bubbler	x	<1.0			
2-B	HS-DW-2-B	Main Lobby	Bottle filler	x	<1.0			
3	HS-BF-3	Faculty Restroom	Faucet		N/A		Mixing Valves	
4	HS-BF-4	Faculty Restroom	Faucet		N/A		Mixing Valves	
5	HS-SC-5	Boiler Room	Hose Bib		N/A		N/A	
6	HS-CF-6	Faculty Lounge	Faucet		N/A		Does Not Exist	
7	HS-KF-7	Room 205	Faucet	X	<1.0			
8	HS-BF-8	100 Wing Boy's	Faucet		N/A		Mixing Valves	
9	HS-BF-9	100 Wing Boy's	Faucet		N/A		Mixing Valves	
10	HS-BF-10	100 Wing Girl's	Faucet		N/A		Mixing Valves	
11	HS-BF-11	100 Wing Girl's	Faucet		N/A		Mixing Valves	
12	HS-NF-12	Nurse's Office	Faucet	x	<1.0			
13	HS-NI-13	Nurse's Office- Ice	Faucet	x	<1.0			
14	HS-BF-14	Nurse Restroom	Faucet	x	N/A		Mixing Valves	
15	HS-CF-15	Ath. Trainer	Faucet	x	13.5			
16	HS-BF-16	Girl's PE Office	Faucet		N/A		Off Due to COVID	
17	HS-BF-17	Girl's PE Locker	Faucet		N/A		Off Due to COVID	
18	HS-CF-18	Boy's PE Office	Faucet		N/A		Off Due to COVID	
19	HS-BF-19	Boy's PE Locker	Faucet		N/A		Off Due to COVID	
20	HS-DW-20	100 Wing Fountain	Bubbler Left	x	<1.0			
21	HS-DW-21	100 Wing Fountain	Bubbler Right	x	<1.0			
21-A	HS-DW-21-A	100 Wing Fountain	Bubbler Bottle Filler	x	<1.0			
22	HS-CF-22	Room 105 Tech	Faucet		N/A		N/A	
23	HS-CF-23	Room 112	Faucet		N/A		Off Due to COVID	
24	HS-DW-24	Room 112	Faucet		N/A		Off Due to COVID	
25	HS-CF-25	Room 112	Faucet		N/A		Off Due to COVID	

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
		DW Drinking Water Fountain
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		KBF Kitchen Bathroom Sink Faucet
Lab: Pace Labs		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	10:15am-10:52am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	High School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
26	HS-CF-26	Room 112	Lab Faucet					N/A
27	HS-BF-27	Kitchen RR	Faucet	x	3.4			Hand Washing Only
28	HS-KF-28	Kitchen	Faucet Sprayer	x			48.4	Out of service- New sprayer is on order
29	HS-KF-29	Kitchen	Faucet	x	3.5			2- Bay Sink
30	HS-KF-30	Kitchen	Faucet	x	1.4			Dish Machine Sprayer
31-A	HS-DW-31	Café	Bubbler Left	x	1.4			
31-B	HS-DW-31	Café	Bubbler Right	x	1.6			
32	HS-KF-32	Kitchen	Faucet		N/A			Not Used- Dish Room
33	HS-CF-33	Room 113	Lab Faucet		N/A			N/A
34	HS-CF-34	Room 113	Lab Faucet		N/A			N/A
35	HS-CF-35	Room 401	Lab Faucet		N/A			N/A
36	HS-CF-36	Room 401	Lab Faucet		N/A			N/A
37	HS-CF-37	Room 401	Lab Faucet		N/A			N/A
38	HS-CF-38	Room 401	Lab Faucet		N/A			N/A
39	HS-CF-39	Room 401	Lab Faucet		N/A			N/A
40	HS-CF-40	Room 401	Lab Faucet		N/A			N/A
41	HS-CF-41	Room 401	Lab Faucet		N/A			N/A
42	HS-CF-42	Room 401	Lab Faucet		N/A			N/A
43	HS-CF-43	Room 401	Lab Faucet		N/A			N/A
44	HS-CF-44	Room 401	Lab Faucet		N/A			N/A
45	HS-CF-45	Room 401	Lab Faucet		N/A			N/A
46	HS-CF-46	Room 401	Lab Faucet		N/A			N/A
47	HS-CF-47	Room 401	Lab Faucet		N/A			N/A
48	HS-CF-48	Room 401	Lab Faucet		N/A			N/A
49	HS-CF-49	Room 401	Lab Faucet		N/A			N/A
50	HS-CF-50	Room 402	Lab Faucet		N/A			N/A

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
		DW Drinking Water Fountain
		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
		NI Nurse's Ice Machine
		NF Nurse's Sink Faucet
		SC Service Connection
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		
Lab: Pace Labs		
Contact:		
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	10:15am-10:52am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	High School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDATION
					> 15ppb	15-19ppb	< 20ppb	
51	HS-CF-51	Room 402	Lab Faucet		N/A			
52	HS-CF-52	Room 402	Lab Faucet		N/A			
53	HS-CF-53	Room 402	Lab Faucet		N/A			
54	HS-CF-54	Room 404	Lab Faucet		N/A			
55	HS-CF-55	Room 406	Lab Faucet		N/A			
56	HS-CF-56	Room 406	Lab Faucet		N/A			
57	HS-CF-57	Room 406	Lab Faucet		N/A			
58	HS-CF-58	Room 406	Lab Faucet		N/A			
59	HS-CF-59	Room 406	Lab Faucet		N/A			
60	HS-CF-60	Room 406	Lab Faucet		N/A			
61	HS-CF-61	Room 406	Lab Faucet		N/A			
62	HS-CF-62	Room 406	Lab Faucet		N/A			
63	HS-CF-63	Room 406	Lab Faucet		N/A			
64	HS-CF-64	Room 406	Lab Faucet		N/A			
65	HS-CF-65	Room 406	Lab Faucet		N/A			
66	Ps-CF-66	Room 403	Lab Faucet		N/A			
67	HS-CF-67	Room 403	Lab Faucet		N/A			
68	HS-CF-68	Room 403	Lab Faucet		N/A			
69	HS-CF-69	Room 403	Lab Faucet		N/A			
70	HS-CF-70	Room 403	Lab Faucet		N/A			
71	HS-CF-71	Room 403	Lab Faucet		N/A			
72	HS-CF-72	Room 403	Lab Faucet		N/A			
73	HS-CF-73	Room 403	Lab Faucet		N/A			
74	HS-CF-74	Room 405	Lab Faucet		N/A			
75	HS-CF-75	Room 405	Lab Faucet		N/A			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		DW Drinking Water Fountain
Lab: Pace Labs		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	10:15am-10:52am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	High School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) Outlet Information

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDATION
					> 15ppb	15-19ppb	< 20ppb	
76	HS-CF-76	Room 409	Lab Faucet		N/A			
77	HS-KF-77	Room 409	Lab Faucet		N/A			
78	HS-DW-78	Room 409	Lab Faucet		N/A			
79	HS-CF-79	Room 409	Lab Faucet		N/A			
80	HS-CF-80	Room 409	Lab Faucet		N/A			
81	HS-CF-81	Room 409	Lab Faucet		N/A			
82	HS-CF-82	Room 409	Lab Faucet		N/A			
83	HS-CF-83	Room 409	Lab Faucet		N/A			
84	HS-CF-84	Room 409	Lab Faucet		N/A			
85	HS-CF-85	Room 409	Lab Faucet		N/A			
86	HS-CF-86	Room 409	Lab Faucet		N/A			
87	HS-CF-87	Room 409	Lab Faucet		N/A			
88	HS-CF-88	Room 411	Lab Faucet		N/A			
89	HS-CF-89	Room 411	Lab Faucet		N/A			
90	HS-CF-90	Room 411	Lab Faucet		N/A			
91	HS-CF-91	Room 411	Lab Faucet		N/A			
92	HS-CF-92	Room 411	Lab Faucet		N/A			
93	HS-CF-93	Room 411	Lab Faucet		N/A			
94	HS-CF-94	Room 411	Lab Faucet		N/A			
95	HS-CF-95	Room 410	Lab Faucet		N/A			
96	HS-CF-96	Room 410	Lab Faucet		N/A			
97	HS-CF-97	Room 410	Lab Faucet		N/A			
98	HS-CF-98	Room 410	Lab Faucet		N/A			
99	HS-CF-99	Room 410	Lab Faucet		N/A			
100	HS-CF-100	Room 410	Lab Faucet		N/A			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		DW Drinking Water Fountain
Lab: Pace Labs		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection

## CLIENT INFORMATION

Name: Ichabod Crane Central School District
Address: 2910 Route 9 Valatie, New York 12184
Client Rep: Steven Marotta

Date of Sampling:	4/24/2021
Samples Taken By:	SM
Samples Taken By:	10:15am-10:52am

## SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	High School
BLDG ADDRESS:	
CONTACT NAME & NUMBERS:	Steven Marotta (518) 758-7575 x 3501

## SAMPLE DATA

Sample Description ID (ID must match container label) **Outlet Information**

Lab Sample #	Ichabod Sample No.	Location	Outlet Description	First Draw	LAB RESULTS LEAD			REMEDIATION
					> 15ppb	15-19ppb	< 20ppb	
101	HS-BF-101	400 Wing Women's	Faucet	x	<1.0			
102	HS-BF-102	400 Wing Women's	Faucet	x	<1.0			
103	HS-BF-103	400 Wing Women's	Faucet	x	<1.0			
104	HS-DW-104	400 Wing	Bubbler	x		17.2		Out of service. New Bubbler will be installed over the summer
105	HS-BF-105	400 Wing Men's	Faucet	x	2			
106	HS-BF-106	400 Wing Men's	Faucet	x	<1.0			
107	<del>HS-CF-107</del>	<del>Room 305</del>	<del>Lab Faucet</del>	x	N/A			N/A
108	HS-DW-108	300 Wing	Bubbler	x	<1.0			
109	HS-DW-109	300 Wing	Bubbler	x	<1.0			
109-A	HS-DW-109-A	300 Wing	Bottle Filler	X	<1.0			
110	HS-KF-110	C.O. Kitchen	Faucet	x	6.8			
111	HS-BF-111	C.O. Bathroom	Faucet	x	1.4			
112	<del>HS-CF-112</del>	<del>Music Suite Sink</del>	<del>Faucet</del>	x	N/A			N/A
113	HS-LF-113	Library Work Room	Faucet	x		24.1		Posted "Do not drink from this outlet" No Further Action
114	<del>HS-HB-114</del>	<del>Courtyard</del>	<del>HOSE BIB</del>	x	N/A			N/A
115	<del>HS-HB-115</del>	<del>400 Wing</del>	<del>HOSE BIB</del>	x	N/A			N/A
116	<del>HS-HB-116</del>	<del>400 Wing</del>	<del>HOSE BIB</del>	x	N/A			N/A
117	HS-DW-117	200 Wing	Bubbler	x	<1.0			
118	HS-KF-118	M.O. Kitchen	Faucet	x	<1.0			
119	HS-CF-119	Room 100 L	Faucet	x	<1.0			
120	HS-CF-120	Room 100 R	Faucet	x	<1.0			
121	HS-CF-121	Room 102 L	Faucet	x	<1.0			
122	HS-CF-122	Room 102 R	Faucet	x	<1.0			
123	HS-CF-123	Room 203 L	Faucet	x	<1.0			
124	HS-CF-124	Room 203 R	Faucet	x	<1.0			

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

## CHAIN OF CUSTODY

Relinquished By:	Received By:	Legend
		BF Bathroom Faucet
		CF Classroom Faucet
INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb) only		DW Drinking Water Fountain
Lab: Pace Labs		KBF Kitchen Bathroom Sink Faucet
		KF Kitchen Sink Faucet
		LF Library Faucet
Contact:		NI Nurse's Ice Machine
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		NF Nurse's Sink Faucet
		SC Service Connection





